

PRODUCT-DETAILS

F202 AC-16/0.01 F202 AC-16/0.01 Residual Current Circuit Breaker



General Information		
Extended Product Type	F202 AC-16/0.01	
Product ID	2CSF202001R0160	
EAN	8012542779902	
Catalog Description	F202 AC-16/0.01 Residual Current Circuit Break	
Long Description	The RCCBs F200 series assures protection to people and installations against fault content to earth. A large offer for standard instantaneous and selective AC and A types is community with some configurations for special applications.	

Eco Transparency Environmental Product 9AKK108467A3700 Declaration - EPD

Technical	
Standards	IEC/EN 61008 UL 1053
Type of Residual Current	AC type
Rated Voltage (U _r)	230 V
Rated Operational Voltage	230 V
Rated Insulation Voltage	500 V

ted Impulse Withstand tage (U _{imp}) ted Current (I _n) ted Residual Current ted Conditional Short- cuit Current (I _{nc}) ted Service Short- cuit Breaking Capacity) ximum Surge Current tel kage Current Type
ted Residual Current ted Conditional Short- cuit Current (I _{nc}) ted Service Short- cuit Breaking Capacity) ximum Surge Current 10 m 10 m
ted Conditional Short- cuit Current (I _{nc}) ted Service Short- cuit Breaking Capacity) ximum Surge Current 10 H 20 H 2
cuit Current (I _{nc}) led Service Short- cuit Breaking Capacity) ximum Surge Current 0.25 I
cuit Breaking Capacity) ximum Surge Current 0.25 F
•
ıkage Current Type
red Frequency (f) 50 60 H
wer Loss at Rated Operating Conditions per Pole 1.5
wer Supply Connection Arbitra
ctrical Endurance 10000 cyc
mber of Poles
erating Characteristic Instantaneou
unting Type DIN r.
tions Provided No
cessories Available Yo
nnecting Capacity Busbar 10 mr Rigid 25 25 mr Flexible 25 25 mr
ted Cross-Section 4 - Multi-Wired 025 mr 1 - Solid-Core 2525 mr
nvironmental
bient Temperature -2555 °
bient Air Temperature Operation -2555 ^o
gree of Protection IP2
lution Degree
lution Degree sistance to Vibrations 0.1 mm or 1 g - 20 cycles at 51505 H to IEC 60068-2-6
sistance to Vibrations 0.1 mm or 1 g - 20 cycles at 51505 H
sistance to Vibrations 0.1 mm or 1 g - 20 cycles at 51505 h to IEC 60068-2-6 sistance to Shock acc. 25g 2 shocks 13 m
sistance to Vibrations 0.1 mm or 1 g - 20 cycles at 51505 h to IEC 60068-2-6 sistance to Shock acc. 25g 2 shocks 13 m EC 60068-2-27
Sistance to Vibrations 0.1 mm or 1 g - 20 cycles at 51505 h to IEC 60068-2-6 Sistance to Shock acc. 25g 2 shocks 13 m EC 60068-2-27 HS Status Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 20
sistance to Vibrations 5. to IEC 60068-2-6 5. sistance to Shock acc. 5. sistance to Shock acc. 5. sistance to Shock acc. 6. sistance to Shock acc. 7. sistance to Shock acc. 8. sistance to Shock acc. 8

Width in Number of 2

9AKK107991A6127

Instructions and Manuals

Modular Spacings	
Product Net Width	0.035 n
Product Net Height	0.085 m
Product Net Depth / Length	0.069 m
Product Net Weight	0.200 kg
Built-In Depth (t ₂)	69 mm
Container Information	
Package Level 1 Units	box 1 piece
Package Level 1 Width	80 mm
Package Level 1 Height	41 mm
Package Level 1 Depth / Length	94 mm
Package Level 1 Gross Weight	0.235 kg
Package Level 1 EAN	8012542779902
Package Level 2 Units	box 6 piece
Package Level 2 Width	96 mm
Package Level 2 Height	85 mm
Package Level 2 Depth / Length	240 mm
Package Level 2 Gross Weight	1350 g
Package Level 2 EAN	8012542779919
Ordering	
Minimum Order Quantity	1 piece
Customs Tariff Number	85363030
Country of Origin	Italy (IT)
Contification and Deplacetions (Department Number)	
Certificates and Declarations (Document Number)	
Declaration of Conformity - CE	9AKK106713A5602
Environmental Information	Refer to RoHS
Environmental Product Declaration - EPD	9AKK108467A3700
Instructions and Manuals	9AKK107991A6127
RoHS Information	9AKK106713A5602
Popular Downloads	
Data Sheet, Technical Information	9AKK107991A8329
	0.41/1/4.07004.4.04.07

Classifications			
ETIM 7	EC000003 - Residual current circuit breaker (RCCB)		
ETIM 8	EC000003 - Residual current circuit breaker (RCCB)		
EPLAN Catalog Tree	Electrical engineering / Protection devices / Ground fault current circuit breake		
EPLAN Function Definition	Ground fault current circuit-breaker / Ground fault current circuit breakers, 4 connection points / Ground fault current circuit breaker, two-pole 1/2 2/1 3/4 4/3		
WEEE Category	5. Small Equipment (No External Dimension More Than 50 cm)		
WEEE B2C / B2B	Business To Consumer		
CN8	85363030		
UNSPSC	39121601		
eClass	V11.0 : 27142201		
IDEA Granular Category Code (IGCC)	4875 >> Residual current circuit breaker (RCCB)		
Object Classification Code	F		

Accessories				
Identifier	Description	Туре	Quantity	Unit Of Measure
2CDS200912R0001	S2C-H6R Auxiliary Contact	S2C-H6R	2	piece
2CDS200922R0001	S2C-S/H6R Signal / Auxiliary Contact	S2C-S/H6R	2	piece
2CDS200946R0001	S2C-H6-11R Auxiliary Contact	S2C-H6-11R	1	piece
2CDS200946R0003	S2C-H6-02R Auxiliary Contact	S2C-H6-02R	1	piece
2CDS200946R0002	S2C-H6-20R Auxiliary Contact	S2C-H6-20R	1	piece
2CSS200933R0011	F2C-A1 Shunt trip	F2C-A1	1	piece
2CSS200933R0012	F2C-A2 Shunt trip	F2C-A2	1	piece
2CSS200911R0005	S2C-UA 230 AC Undervoltage release	S2C-UA 230 AC	1	piece
2CSS200911R0007	S2C-UA 24 DC Undervoltage release S2C-UA 24 DC			piece
2CSS200911R0002	S2C-UA 24 AC Undervoltage release S2C-UA 24 AC		1	piece
2CSS200911R0008	S2C-UA 48 DC Undervoltage release S2C-UA 48 DC		1	piece
2CSS200911R0004	S2C-UA 110 AC Undervoltage release	S2C-UA 110 AC	1	piece
2CSS200911R0006	S2C-UA 400 AC Undervoltage release	S2C-UA 400 AC	1	piece
2CSS200911R0001	S2C-UA 12 DC Undervoltage release S	S2C-UA 12 DC	1	piece
2CSS200911R0010	S2C-UA 230 DC Undervoltage release	S2C-UA 230 DC	1	piece
2CSS200911R0009	S2C-UA 110 DC Undervoltage release	S2C-UA 110 DC	1	piece
2CSS200911R0003	S2C-UA 48 AC Undervoltage release \$	S2C-UA 48 AC	1	piece
2CSS200910R0005	S2C-OVP1 Overvoltage release	S2C-OVP1	1	piece
2CSS200993R0005	S2C-OVP2 Overvoltage release	S2C-OVP2	1	piece
2CSF200997R0013	F2C-CM Motor operating device	F2C-CM	1	piece
2CSF200996R0013	F2C-ARI Auto-reclosing unit	F2C-ARI	1	piece

F202 AC-16/0.01

Categories

 $Low\ Voltage\ Products\ and\ Systems\ \to\ Modular\ DIN\ Rail\ Products\ \to\ Residual\ Current\ Devices\ RCDs\ \to\ Residual\ Resi$

